

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**Power-Genex Ltd.**  
**44B9L, 434-9, Nonhyun-ding, Namdong-gu**  
**406-848 Incheon, South-Korea**

the Certificate No: **Z01802** for the PROFIBUS Device:

**Model Name: SSPA**  
**Revision: 1.0; SW/FW: 01.00; HW: 01.00**  
**GSD: PWGX0E19.GSD, File Version: 5.0**  
**pa139710.gsd**

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Sync, Freeze, Fail_Safe, Set_Slave_Add
<input checked="" type="checkbox"/>	DP-V1	MS1, Prm_Block_Structure, MS2, I&M
<input checked="" type="checkbox"/>	Profile	PROFIBUS PA 3.02
<input checked="" type="checkbox"/>	Physical Layer	MBP

**Test Report Number: MCDL-2013-562-D**  
**Authorized Test Laboratory: ITEI, Beijing, China**

The tests were executed in accordance with the following documents:  
 "Test Specifications for PROFIBUS DP Slaves, Version 3.0.9, September 2008" and  
 "Test Specifications for PROFIBUS PA Profile 3.0.2, Version 5.0.4, February 2010".

This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by October 15, 2016 the certificate is valid for life.


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)

(K.-P. Lindner)