

## TEST REPORT

### 1. Applicant

Name : POWER-GENEX LTD.  
Address : 99, Eunbong-ro, Nonhyun-dong, Namdong-gu,  
Incheon, Korea

### 2. Products

Name : Valve Position Monitor  
Model/Type : LSB1000  
Manufacturer : POWER-GENEX LTD.  
Remark : -

3. Test Standard/Method : IEC 60529:2001, KS C IEC 60529:2006


4. Test Results : IP68 (Refer to document)

5. Use of Report : For Quality Control

6. Date of Application : 2014. 03. 10


7. Date of Issue : 2014. 03. 17

Tested by



Base Technology Center  
Chang-ho Kim

Approved by



Base Technology Center  
Leader Jun-gu Kang

*The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.*

# Korea Testing Laboratory



87, Digital 26-gil, Guro-gu, Seoul, Korea (152-718)  
<http://www.ktl.re.kr>

Tel. : +82-2-860-1531  
Fax. : +82-2-860-1549

