



# Safety Certificate

**POWER-GENEX CO.,LTD.**

44B9L, 434-9, Nonhyun-dong, Namdong-gu, Incheon, Korea

The following product produced by the above company has been authorized for the use of the KCS Mark as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

### PRODUCT

Smart Valve Positioner

### TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL	CAPACITY · GRADE	CERTIFICATION No.
SS(L/R)-F*****	Ex d IIB+H <sub>2</sub> T6 IP66 (Input signal : 4~20mA DC, T <sub>a</sub> = -20 °C ~ +60 °C)	11-AV2BO-0156

### SAFETY CERTIFICATION STANDARDS

Notification of Ministry of Labor No. 2010-36

### CERTIFICATION CONDITION

- It is only for the product manufactured at "44B9L, 434-9, Nonhyun-dong, Namdong-gu, Incheon, Korea"

DATE : Aug. 24, 2011  
June. 07, 2011(Original issue)

Signature Baek Hun Ki

**President of Korea Occupational Safety and Health Agency**



# 안 전 인 증 서

## 파워제넥스(주)

인천광역시 남동구 논현동 434-9

위 사업장에서 제조하는 아래의 품목이 「산업안전보건법」 제34조 및 같은 법 시행규칙 제58조의4에 따른 안전인증 심사결과 안전·보건 기준에 적합하므로 안전인증표시의 사용을 인증합니다.

### 품 목

Smart Valve Positioner

### 형식·모델/용량·등급/인증번호

형식·모델	용량·등급	인증번호
SS(L/R)-F*****	Ex d IIB+2 T6 IP 66 (Input signal : 4 ~ 20 mA DC, 주위온도 -20 °C ~ +60 °C)	11-AV2BO-0156

### 인 증 기 준

방호장치 의무안전인증 고시(노동부고시 제2010-36호)

### 인 증 조 건

· "인천광역시 남동구 논현동 434-9"에서 생산하는 제품에 한함

2011년 06월 07일

## 한국산업안전보건공단 이사장

