

IECEX Technical Report: KR/KTL/ExTR11.0024/00 details

ExTR :	
ExTR Reference Number *: (automatic numbering)	KR/KTL/ExTR11.0024/00
Status*:	Issued
ExTR Free Reference Number*:	KR/KTL/ExTR11.0024/00
Date of Issue*: (yyyy-mm-dd)	2011-12-09
List of Standards Covered*:	IEC 60079-0 (Ed.6.0); IEC 60079-1 (Ed.6)
Issuing ExTL*:	KTL - Korea Testing Laboratory
Endorsing ExCB*:	KTL - Korea Testing Laboratory
Manufacturer*:	Power-Genex Ltd. 44B9L, 434-9, Nonhyun-dong, Namdong-Gu, Incheon, 405-849
Country of Manufacture*:	Korea, Republic of
Ex Protection*:	Flameproof enclosure "d" Ex d IIB+H2 T6
Ratings:	Operating Voltage : 24VDC / 220VAC / 110VAC Power : 4.9W(AC 60Hz) or 2.5W (DC)
Product*:	Vavle Monitoring Controller
Model Reference*:	LSB-7 series
Related IECEx Certificates:	IECEX KTL 11.0021X issue: 0 [Current]
Comment:	
Attachment:	