

IECEX Technical Report: KR/KTL/ExTR11.0023/00 details

ExTR :	
ExTR Reference Number *: (automatic numbering)	KR/KTL/ExTR11.0023/00
Status*:	Issued
ExTR Free Reference Number*:	KR/KTL/ExTR11.0023/00
Date of Issue*: (yyyy-mm-dd)	2011-12-09
List of Standards Covered*:	IEC 60079-0 (Ed.6.0); IEC 60079-1 (Ed.6)
Issuing ExTL*:	KTL - Korea Testing Laboratory
Endorsing ExCB*:	KTL - Korea Testing Laboratory
Manufacturer*:	Power-Genex Ltd. 44B9L, 434-9, Nonhyun-dong, Namdong-Gu, Incheon, 405-849
Country of Manufacture*:	Korea, Republic of
Ex Protection*:	Flameproof enclosure "d" Ex d IIC T6
Ratings:	Input signal : 4~2 mA @ 24 VDC Min. / Max. current : 3.6 mA / 50mA Voltage drop(impedance) : - 8.7 VDC (without HART) - 9.4 VDC (with HART)
Product*:	Smart Positioner
Model Reference*:	SS3 series (SS3L, SS3R)
Related IECEX Certificates:	IECEX KTL 11.0020 issue: 0 [Current]
Comment:	
Attachment:	