



# 中国国家强制性产品认证证书



证书编号：2020322307001291

认证委托人名称：帕尔-吉尼克斯株式会社  
 认证委托人地址：韩国仁川广域市南洞区论岷洞 434-9, 44B9L  
 生产者名称：帕尔-吉尼克斯株式会社  
 生产者地址：韩国仁川广域市南洞区论岷洞 434-9, 44B9L  
 生产企业名称：帕尔-吉尼克斯株式会社  
 企业地址：韩国仁川广域市南洞区论岷洞 434-9, 44B9L

产品名称：智能阀门定位器  
 系列、规格、型号：SS3ab-cdefghij  
 标准：GB 3836.1-2010、GB 3836.2-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月14日      有效期至：2025年9月13日

首次发证日期：2020年9月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准：



## 上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322307001291**

**APPLICANT:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**MANUFACTURER:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**FACTORY:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**PRODUCTNAME:** Smart Valve Positioner  
**SERIES,SPECIFICATION,MODEL:** SS3ab-cdefghij  
**STANDARDS:** GB 3836.1-2010、 GB 3836.2-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**September 14, 2020                      **Valid until:** September 13, 2025

**Date of original certification:**September 14, 2020

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



**APPROVAL:**   
 Xu JianPing



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0000865



# 中国国家强制性产品认证证书



证书编号: 2020322307001291

## 附件

产品名称: 智能阀门定位器

型号规格: SS3 **ab-cdefghij** 其中:

- a** 表示 body material, 可为: Blank – aluminum die-cast, S – stainless steel
- b** 表示 actuator action, 可为: L – Linear type, R - Rotary type
- c** 表示 Ex protection type, 可为: F – Flameproof enclosure “d”(Ex d IIC T6)
- d** 表示 feedback lever, 可为: A, B, C, D, F, N
- e** 表示 pressure gauge, 可为: 0, 1, 2
- f** 表示 position feedback, 可为: N, O, L, S, M, Q
- g** 表示 communication, 可为: N, H, F, P
- h** 表示 pneumatic electrical connections, 可为: 4, 5
- i** 表示 mounting bracket, 可为: N, L, R
- j** 表示 feedback pin guide, 可为: 0, 1

防爆标志: Ex d IIC T6 Gb

电气参数: 额定值: 输入信号4-20mA(24VDC)

批准:



## 上海仪器仪表自控系统检验测试所有限公司