



中国国家强制性产品认证证书



证书编号：2020322307001291

认证委托人名称：帕尔-吉尼克斯株式会社
 认证委托人地址：韩国仁川广域市南洞区论岬洞 434-9, 44B9L
 生产者名称：帕尔-吉尼克斯株式会社
 生产者地址：韩国仁川广域市南洞区论岬洞 434-9, 44B9L
 生产企业名称：帕尔-吉尼克斯株式会社
 企业地址：韩国仁川广域市南洞区论岬洞 434-9, 44B9L
 产品名称：智能阀门定位器
 系列、规格、型号：SS3ab-cdefghij
 标准：GB/T 3836.1-2021、GB/T 3836.2-2021

认证模式：型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求，特发此证。产品相关信息详见附件。

发证日期：2023年04月19日

有效期至：2025年09月13日

首次发证日期：2020年09月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322307001291

APPLICANT: POWER-GENEX LTD
ADDRESS: 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA
MANUFACTURER: POWER-GENEX LTD
ADDRESS: 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA
FACTORY: POWER-GENEX LTD
ADDRESS: 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

PRODUCT: Smart Valve Positioner
SERIES,SPECIFICATION,MODEL: SS3ab-cdefghij
STANDARDS: GB/T 3836.1-2021、 GB/T 3836.2-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection
 This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from:April 19, 2023 **Valid until:**September 13, 2025

Date of original certification:September 14, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0007377



中国国家强制性产品认证证书



证书编号: 2020322307001291

附件

产品名称: 智能阀门定位器

型号规格: SS3ab-cdefghij

a 表示 body material, 可为: Blank – aluminum die-cast, S – stainless steel

b 表示 actuator action, 可为: L – Linear type, R – Rotary type

c 表示 Ex protection type, 可为: F – Flameproof enclosure “d”

d 表示 feedback lever, 可为: A, B, C, D, F, N

e 表示 pressure gauge, 可为: 0, 1, 2

f 表示 position feedback, 可为: N, O, L, S, M, Q

g 表示 communication, 可为: N, H, F, P

h 表示 pneumatic electrical connections, 可为: 4, 5

i 表示 mounting bracket, 可为: N, L, R

j 表示 feedback pin guide, 可为: 0, 1

防爆标志: Ex db IIC T6 Gb

电气参数: 输入信号4-20mA(24VDC)

相关报告编号: 2020S17402-001113、2022S17402-009972

批准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2020322307001291

附 件

使用条件：

- 1、涉及隔爆接合面的维修须联系产品制造商。
- 2、产品隔爆接合面的紧固件性能等级为 A2-50。
- 3、产品使用环境温度范围为：-30℃~+75℃。

批 准：



上海仪器仪表自控系统检验测试所有限公司