



中国国家强制性产品认证证书



证书编号：2020322307001902

认证委托人名称：帕尔-吉尼克斯株式会社
 认证委托人地址：韩国仁川广域市南洞区论岾洞 434-9, 44B9L
 生产者名称：帕尔-吉尼克斯株式会社
 生产者地址：韩国仁川广域市南洞区论岾洞 434-9, 44B9L
 生产企业名称：帕尔-吉尼克斯株式会社
 企业地址：韩国仁川广域市南洞区论岾洞 434-9, 44B9L

产品名称：电气阀门定位器
 系列、规格、型号：EPa-bcdefghij
 标准：GB 3836.1-2010、GB 3836.2-2010、GB 3836.9-2014

上述产品符合强制性产品认证实施规则 CNCA-G23-01:2019 的要求，特发此证。

发证日期：2020年9月24日 有效期至：2025年9月23日

首次发证日期：2020年9月24日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0002302



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322307001902

APPLICANT: POWER-GENEX LTD
ADDRESS: 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA
MANUFACTURER: POWER-GENEX LTD
ADDRESS: 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA
FACTORY: POWER-GENEX LTD
ADDRESS: 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

PRODUCTNAME: Electro-Pneumatic Positioner

SERIES,SPECIFICATION,MODEL: EPa-bcdefghij

STANDARDS: GB 3836.1-2010、GB 3836.2-2010、GB 3836.9-2014

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 24, 2020

Valid until: September 23, 2025

Date of original certification:September 24, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001179



中国国家强制性产品认证证书



证书编号：2020322307001902

附件

产品名称： 电气阀门定位器

型号规格： EP **a-bcdefghij** 其中：

- a** 代表actuator action, 可为: L - Linear type, R-Rotary type;
- b** 代表protection class, 可为: D - Ex d mb II C T6;
- c** 代表feedback lever, 可为: N, A, B, C;
- d** 代表pressure gauge, 可为: 1, 2;
- e** 代表pilot valve orifice, 可为: S, M;
- f** 代表position feedback, 可为: N, O, L, P, M, Q;
- g** 代表connection threads, 可为: 4, 5;
- h** 代表dome indicator(only for rotary type), 可为: N, D;
- i** 代表ambient temperature, 可为: T, H;
- j** 代表mounting bracket, 可为: N, L, R, F, E;

防爆标志： Ex d mb II C T6 / T5 Gb

电气参数： 额定值： 输入信号4-20mA DC

批 准：



上海仪器仪表自控系统检验测试所有限公司