



# 中国国家强制性产品认证证书



证书编号：2020322307001281

认证委托人名称：帕尔-吉尼克斯株式会社  
 认证委托人地址：韩国仁川广域市南洞区论岾洞 434-9, 44B9L  
 生产者名称：帕尔-吉尼克斯株式会社  
 生产者地址：韩国仁川广域市南洞区论岾洞 434-9, 44B9L  
 生产企业名称：帕尔-吉尼克斯株式会社  
 企业地址：韩国仁川广域市南洞区论岾洞 434-9, 44B9L

产品名称：电气阀门定位器  
 系列、规格、型号：EPa-bcdefghij  
 标准：GB 3836.1-2010、GB 3836.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月14日                      有效期至：2025年9月13日

首次发证日期：2020年9月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准：



## 上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0001346



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**SITILAS**  
Worldwide Access

**CERTIFICATE NO: 2020322307001281**

**APPLICANT:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**MANUFACTURER:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**FACTORY:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**PRODUCTNAME:** Electro-Pneumatic Positioner  
**SERIES,SPECIFICATION,MODEL:** EPa-bcdefghij  
**STANDARDS:** GB 3836.1-2010、GB 3836.4-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**September 14, 2020

**Valid until:** September 13, 2025

**Date of original certification:**September 14, 2020

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Xu JianPing



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0000861



# 中国国家强制性产品认证证书



**SITIiAS**  
Worldwide Access

证书编号: 2020322307001281

## 附件

产品名称: 电气阀门定位器

型号规格: EP **a-b c d e f g h i j** 其中:

- a** 代表actuator action, 可为: L - Linear type, R-Rotary type;
- b** 代表Ex-Protection Type, 可为: I - Intrinsic safety(Ex ia IIC T6);
- c** 代表feedback Shaft, 可为: A, B, C, A, N;
- d** 代表pressure gauge, 可为: 1, 2;
- e** 代表pilot valve orifice, 可为: S, M;
- f** 代表position feedback, 可为: N-None;
- g** 代表connection threads, 可为: 3, 4, 5;
- h** 代表dome indicator, 可为: N, D;
- i** 代表High temperature, 可为: T-70°C(std);
- j** 代表mounting bracket, 可为: N, L, R, F。

防爆标志: Ex ia IIC T6 Ga

电气参数: 额定值:  $U_i = 28V$ ,  $I_i = 100mA$ ,  $P_i = 1.0W$ ,  $C_i = 0$ ,  $L_i = 2\mu H$

批 准:



## 上海仪器仪表自控系统检验测试所有限公司