



# 中国国家强制性产品认证证书



证书编号：2020322307001284

认证委托人名称：帕尔-吉尼克斯株式会社  
 认证委托人地址：韩国仁川广域市南洞区论岷洞 434-9, 44B9L  
 生产者名称：帕尔-吉尼克斯株式会社  
 生产者地址：韩国仁川广域市南洞区论岷洞 434-9, 44B9L  
 生产企业名称：帕尔-吉尼克斯株式会社  
 生产企业地址：韩国仁川广域市南洞区论岷洞 434-9, 44B9L  
 产品名称：阀位指示控制器  
 系列、规格、型号：LSB-7 ab - c - de - fgh - ij  
 标准：GB/T 3836.1-2021、GB/T 3836.2-2021

认证模式：型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求，特发此证。产品相关信息详见附件。

发证日期：2023年04月19日

有效期至：2025年09月13日

首次发证日期：2020年09月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准：



## 上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0008939



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322307001284**

**APPLICANT:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**MANUFACTURER:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**FACTORY:** POWER-GENEX LTD  
**ADDRESS:** 44B9L,434-9,NONHYEON-DONG,NAMDONG-GU,INCHEON, KOREA

**PRODUCT:** Valve Monitoring Controller  
**SERIES,SPECIFICATION,MODEL:** LSB-7 ab - c - de - fgh - ij  
**STANDARDS:** GB/T 3836.1-2021、 GB/T 3836.2-2021

**Type of Certification: Type test + Initial inspection + Surveillance inspection**

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Refer to the attachment for detailed information.

**Valid from:**April 19, 2023

**Valid until:**September 13, 2025

**Date of original certification:**September 14, 2020

**The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007375



# 中国国家强制性产品认证证书



证书编号: 2020322307001284

## 附件

产品名称: 阀位指示控制器

型号规格: LSB-7 *a b-c-d e-f g h-i j*

- a* 表示 switch type, 可为: 0, 1
- b* 表示 switch/sensor, 可为: N, 0, 2, 4, 6, 7, 8, 9
- c* 表示 position transmitter, 可为: N, O
- d* 表示 coil type, 可为: N, S, D
- e* 表示 pilot power supply, 可为: N, A, B, C
- f* 表示 indicator option, 可为: N, L, T
- g* 表示 electrical connections, 可为: B, C, F, I
- h* 表示 pneumatic connections, 可为: R, N
- i* 表示 feedback shaft, 可为: F, N
- j* 表示 mounting bracket, 可为: N, R

防爆标志: Ex db IIB+H<sub>2</sub> T6 Gb

电气参数: 额定电压24VDC, 220VAC, 110VAC

相关报告编号: 2020S17402-001115、2022S17402-009967

批 准:



### 上海仪器仪表自控系统检验测试所有限公司



# 中国国家强制性产品认证证书



证书编号：2020322307001284

## 附 件

**使用条件：**

- 1、涉及隔爆接合面的维修须联系产品制造商。
- 2、产品隔爆接合面的紧固件性能等级为 A2-50。
- 3、严禁摩擦产品外壳以防静电引燃危险。
- 4、产品使用环境温度范围为：-30°C~+75°C。

批 准：



上海仪器仪表自控系统检验测试所有限公司