



中国国家强制性产品认证证书



证书编号：2020322307001279

认证委托人名称： 帕尔-吉尼克斯株式会社
 认证委托人地址： 韩国仁川广域市南洞区论岾洞 434-9, 44B9L
 生产者名称： 帕尔-吉尼克斯株式会社
 生产者地址： 韩国仁川广域市南洞区论岾洞 434-9, 44B9L
 生产企业名称： 帕尔-吉尼克斯株式会社
 企业地址： 韩国仁川广域市南洞区论岾洞 434-9, 44B9L

产品名称： 电磁阀
 系列、规格、型号： ESV-ab-cd-Fe
 标准： GB 3836.1-2010、GB 3836.2-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月14日 有效期至：2025年9月13日
 首次发证日期：2020年9月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准：



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0001344



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322307001279

APPLICANT: POWER-GENEX LTD
ADDRESS: 44B9L,434-9, NONHYEON-DONG, NAMDONG-GU, INCHEON, KOREA

MANUFACTURER: POWER-GENEX LTD
ADDRESS: 44B9L,434-9, NONHYEON-DONG, NAMDONG-GU, INCHEON, KOREA

FACTORY: POWER-GENEX LTD
ADDRESS: 44B9L,434-9, NONHYEON-DONG, NAMDONG-GU, INCHEON, KOREA

PRODUCTNAME: Solenoid Vavle
SERIES,SPECIFICATION,MODEL: ESV-ab-cd-Fe
STANDARDS: GB 3836.1-2010、 GB 3836.2-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 14, 2020

Valid until: September 13, 2025

Date of original certification:September 14, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0000859



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号: 2020322307001279

附件

产品名称: 电磁阀

型号规格: **ESV-abcd-Fe** 其中:

a 代表operating type, 可为: S(single), D(double), 3(3way), 31(3way spool);

b 代表material, 可为: blank(body and valve: ALDC12.1), S(body: ALDC12.1, valve: SUS316), C(body and valve: SUS316);

c 代表voltage, 可为: A220(220 VAC), A110(110 VAC), D24(24 VDC);

d 代表pipe thread, 可为: N(NPT 1/2), M(M20 x 1.5);

e 代表coil class, 可为: blank(F class), H(H class)。

防爆标志: Ex d IIC T6/T5/T4 Gb

电气参数: 额定电压: (110/220)VAC, (50/60)Hz, 24VDC
额定功率: 9.7VA(220 VAC), 9.9VA(110 VAC), 4.8W(24 VDC)

批 准:



上海仪器仪表自控系统检验测试所有限公司